ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:30 AM	JO	E1A	Kindergarten 1	rinking Fountain	11/16/2017	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	12.49	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:31 AM	JO	E1B	Kindergarten 1	rinking Fountain	11/16/2017	8:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	5.20	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:33 AM	JO	E2A	Kindergarten 1	S - Sink	11/16/2017	8:01 PM	First Draw	250	ARRO Laboratory	EPA 200.5	12.14	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:34 AM	JO	E2B	Kindergarten 1	S - Sink	11/16/2017	8:01 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.14	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:35 AM	JO	E3A	cross From Room 4 Left	F - Water Cooler	11/16/2017	8:05 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.22	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:36 AM	JO	E3B	cross From Room 4 Left	F - Water Cooler	11/16/2017	8:05 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.22	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:38 AM	JO	E4A	ross From Room 4 Right	F - Water Cooler	11/16/2017	8:06 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.77	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:39 AM	JO	E4B	ross From Room 4 Right	F - Water Cooler	11/16/2017	8:06 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.94	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:40 AM	JO	E5A	Multi Purpose Room Left	F - Water Cooler	11/16/2017	8:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:41 AM	JO	E5B	Multi Purpose Room Left	F - Water Cooler	11/16/2017	8:08 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.28	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:42 AM	JO	E6A	urpose Room Bottle Fill	O - Other	11/16/2017	8:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:45 AM	JO	E7A	ulti Purpose Room Right	F - Water Cooler	11/16/2017	8:10 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:46 AM	JO	E7B	ulti Purpose Room Right	F - Water Cooler	11/16/2017	8:10 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:48 AM	JO	E8A	MultiPurpose Room	F - Water Cooler	11/16/2017	8:11 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.48	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:49 AM	JO	E8B	MultiPurpose Room	F - Water Cooler	11/16/2017	8:11 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.65	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:50 AM	JO	E9A	Kitchen Triple	KS - Kitchen Sink	11/16/2017	8:13 PM	First Draw	250	ARRO Laboratory	EPA 200.5	66.60	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:51 AM	JO	E9B	Kitchen Triple	KS - Kitchen Sink	11/16/2017	8:13 PM	Flush	250	ARRO Laboratory	EPA 200.5	4.40	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:53 AM	JO	E10A	Kitchen Pull Down	KS - Kitchen Sink	11/16/2017	8:14 PM	First Draw	250	ARRO Laboratory	EPA 200.5	6.64	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:54 AM	JO	E10B	Kitchen Pull Down	KS - Kitchen Sink	11/16/2017	8:14 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:55 AM	JO	E11A	Kitchen Porcelain Hand	KS - Kitchen Sink	11/16/2017	8:15 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.45	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:56 AM	JO	E11B	Kitchen Porcelain Hand	KS - Kitchen Sink	11/16/2017	8:15 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:57 AM	JO	E12A	Kitchen Single	KS - Kitchen Sink	11/16/2017	8:17 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.39	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	5:58 AM	JO	E12B	Kitchen Single	KS - Kitchen Sink	11/16/2017	8:17 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.61	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:00 AM	JO	E13A	Gym Left	F - Water Cooler	11/16/2017	8:19 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.47	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:01 AM	JO	E13B	Gym Left	F - Water Cooler	11/16/2017	8:19 PM	Flush	250	ARRO Laboratory	EPA 200.5	35.40	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:02 AM	JO	E14A	Gym Right	F - Water Cooler	11/16/2017	8:20 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:03 AM	JO	E14B	Gym Right	F - Water Cooler	11/16/2017	8:20 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:04 AM	JO	E15A	Gym Bottle Filler	O - Other	11/16/2017	8:20 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.19	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:05 AM	JO	E16A	Hall by Boiler Room Left	F - Water Cooler	11/16/2017	8:23 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:07 AM	JO	E16B	Hall by Boiler Room Left	F - Water Cooler	11/16/2017	8:23 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.89	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:09 AM	JO	E17A	all by Boiler Room Right	F - Water Cooler	11/16/2017	8:25 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:10 AM	JO	E17B	all by Boiler Room Right	F - Water Cooler	11/16/2017	8:25 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:12 AM	JO	E18A	Hall Across From 12 Left	F - Water Cooler	11/16/2017	8:26 PM	First Draw	250	ARRO Laboratory	EPA 200.5	35.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:13 AM	JO	E18B	Hall Across From 12 Left	F - Water Cooler	11/16/2017	8:26 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:15 AM	JO	E19A	all Across From 12 Right	F - Water Cooler	11/16/2017	8:27 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:16 AM	JO	E19B	all Across From 12 Right	F - Water Cooler	11/16/2017	8:27 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:18 AM	JO	E20A	Hall by 18 Left	F - Water Cooler	11/16/2017	8:29 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:19 AM	JO	E20B	Hall by 18 Left	F - Water Cooler	11/16/2017	8:29 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:20 AM	JO	E21A	Hall by 18 Right	F - Water Cooler	11/16/2017	8:30 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:21 AM	JO	E21B	Hall by 18 Right	F - Water Cooler	11/16/2017	8:30 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:22 AM	JO	E22A	Hall by 18 Bottle Filler	O - Other	11/16/2017	8:30 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.03	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:24 AM	JO	E23A	Room 19 Double	S - Sink	11/16/2017	8:32 PM	First Draw	250	ARRO Laboratory	EPA 200.5	20.90	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:25 AM	JO	E23B	Room 19 Double	S - Sink	11/16/2017	8:32 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.61	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:27 AM	JO	E24A	Room 19 Single	S - Sink	11/16/2017	8:33 PM	First Draw	250	ARRO Laboratory	EPA 200.5	9.89	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:27 AM	JO	E24B	Room 19 Single	S - Sink	11/16/2017	8:33 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:30 AM	JO	E25A	indergarten 1 Bathroom	S - Sink	11/16/2017	8:35 PM	First Draw	250	ARRO Laboratory	EPA 200.5	4.30	2.00	
470980200022001	st Coloma-Nelson	Elementary School	11/17/17	6:30 AM	JO	E25B	indergarten 1 Bathroom	S - Sink	11/16/2017	8:35 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.83	2.00	